No. S. P. C. 3775-95, dated 15th August 1939.

To

The Firms dealing in Galvanized Wire.

Enquiry No. 3595

GALVANIZED STEEL STRANDED WIRE

GENTLEMEN,

I write to request you to quote your best price and earliest time of delivery for the following material :—

30 Miles.—Extra Galvanized Siemens Martin stranded steel wire, $\frac{3}{8}$" overall diameter, manufactured strictly in accordance with the B.S.S. No. 183 of 1927. The wire should consist of 7 steel galvanised wires twisted together into a single strand and double heavy galvanized. The breaking strength of the wire should be not less than 6,800 lbs., elastic limit 50 per cent. elongation in 24" 10 per cent.

Alternative quotations should be submitted for the supply of the above wire in lengths of one mile each wound on wooden drums properly lagged and protected and in one Cwt. coils suitably covered.

The quotations must be accompanied with full specifications of the material offered along with its breaking strength, elastic limit and percentage elongation in 24".

The successful tenderer will be required to test the wires in accordance with the latest B.S.S. and submit official test certificates.

The price to be quoted should be for delivery, f.o.r., Bangalore.

This enquiry will close on the 10th September 1939.

No. S. P. C. 4569-70, dated 14—15th August 1939.

To

The Firms dealing in Flexible Cords.

Enquiry No. 3597.

FLEXIBLE CORDS.

GENTLEMEN,

I write to request you to quote your best prices and earliest time of delivery for the following materials :—

Item 1.—10,000 ft.—Flexible cord, consisting of 2 extra flexible conductors of tinned copper strands each of size No. 18 S. W. G. or 16 B. & S., having cotton separators and insulated with 2 layers of V.I.R. and braided, suitable for 250-volts A.C. The Conductors after insulation and braiding shall be twisted together.

Item 2.— 3,000 ft.—Worksnop flexible consisting of 2 extra flexible conductors of tinned copper strands each of size 16 S.W.G. or 14 B. & S. and insulated with one layer of pure rubber and 2 layers of V.I.R. twisted together and sheathed over all with a tough rubber compound, for 250-volts, A.C.

Item 3.— 500 ft. — Do do but of size 14 S.W.G. or 12 B. & S.

Item 4.— 500 ft.—Fixture wire consisting of 2 conductors of tinned copper strands each of size 18 S.W.G., or 16 B. & S. and insulated with the best quality asbestos fibre, braided with art silk, suitable for 250-volts A.C.

The above wires shall conform to the latest B.S.S. or A.I.E.E. standards. Full specifications with samples of the materials offered should be submitted along with the quotations together with information on the following points :—

(1) Section of each conductor.
(2) Number of strands in each conductor
(3) Radial thickness of di-electric.
(4) Standard length of manufacture.
(5) D. C. resistance of conductor at 20° C. per 1,000 ft.
(6) D. C. resistance of conductor at 60° C per 1,000 ft.
(7) Overall Diameter
(8) Weight per 1,000 feet of finished wire.

The prices to be quoted should be for delivery, c.i.f., Madras.

This enquiry will close on the 15th September 1939.

No. S. P. C. 3818-38, *dated* 11*th August* 1939.

To

The Firms dealing in Electric Lamps.

Enquiry No. 3598.

FLOOD-LIGHT LAMPS.

GENTLEMEN,

I write to request you to quote your best prices and earliest time of delivery for the following materials :—

Item (1) 350—Flood-light lamps, M.F.G.E.S., 220 volts, 1,000 watts, round bulb, clear, gas-filled, suitable for being used in any burning position with flood-lighting projectors, and of the following approximate dimensions :—Overall length 8″, diameter of bulb 5″ and light centre length 5¼″.

Item (2) 175—Flood-light lamps, M.F.G.E.S., 220 volts, 500 watts, round bulb, clear, gas-filled, suitable for being used in any burning position with flood-lighting projectors, and of the following approximate dimensions:—Overall length 7″, diameter of bulb 5″ and light centre length 4¼″.

The above lamps should conform to the latest B.S.S. or A.I.E.E. standards. Full details with illustrations of the lamps offered should be furnished along with the tenders, together with the following information.

(1) Overall length.
(2) Diameter of bulb.
(3) Light centre length.
(4) Initial lumens (actual).
(5) Initial watts.
(6) Lumens per watt.

The tenderers should also furnish test certificates of the National Physical Laboratory, Teddington, or any other recognised Government Laboratory or the Government of India Test House at Alipore, on representative samples of the lamps offered, along with their quotations.

The successful tenderer will be required to furnish the Factory Test Certificates signed by a responsible Officer along with the supply of lamps.

The prices should be quoted for delivery, f.o.r., Bangalore, which should include the cost of etching the lamps with the letters "GOMED".

This enquiry will close on the 25th September 1939.

The quotations should be sent in duplicate.

No. S. P. C. 4447-56, *dated* 17*th August* 1939.

To

The Firms dealing in Turbans.

Enquiry No. 3606.

DUNGRY TURBANS.

DEAR SIR/GENTLEMEN,

Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the attached schedule, in the form printed below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Dungry Turbans" with the above enquiry Number.

This enquiry will be closed on the 1st September 1939.

Schedule.

Item No.	Description of material offered	Quantity	Price quoted F. O. R.	Time of delivery
	Turbans Dungry, 6 yards long, 22" wide with $\frac{7}{8}$" white border on each side length-wise and 18" black and white mixed border at one end breadthwise	75 Nos.	*Mysore South.*	

N.B.—Samples should accompany your quotation.

No. S. P. C. 4406-25, *dated* 18*th August* 1939.

To

The Firms dealing in Textile Materials.

Enquiry No. 3609.

GENTLEMEN,

Please be good enough to intimate your best prices f.o.r. Bangalore, with samples, for the materials described below :—

Cotton Putties	Khaki, $7\frac{1}{2}' \times 4''$	with tape complete	. .	2,280 Pairs.
Do	Blue	do	. . . .	250 ,,

N.B.—(1) Samples offered against the enquiry should accompany the quotation.
(2) The materials offered should be of fast dye.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

(1) The contract will be in force for one year from the date of letting the contract and the prices quoted should be firm during the above period.
(2) The colour of the dyes used for the materials should be fast. The samples offered will be subjected to test at the Mysore Government Industrial and Testing Laboratory, with a view to examine if the materials are of fast colour. The tender should be accompanied by the necessary test charges at Rs. 10 per sample, without which the tender will not be considered.
(3) Supplies will be required to be made within four weeks from the date of receipt of indents from the indenting officers and in strict conformity to the approved sample.
(4) Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellation of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Cotton Putties" required for the Mysore Government Departments during 1939-40.

This enquiry will be closed on the 20th September 1939.

No. S. P. C. 4457-72, *dated* 17*th August* 1939.

To

The Firms dealing in Transformer Oil.

Enquiry No. 3611.

TRANSFORMER OIL.

GENTLEMEN,

I write to request you to quote your best price and earliest time of delivery for 4,500 gallons of Transformer oil conforming to the specifications, which will be furnished on request.

Detailed specifications for the oil offered must be furnished in your tender. Names of manufacturers of the oil must be specified.

The price to be quoted should be per imperial gallon and for delivery, c.i.f., Madras.
This enquiry will close on the 12th September 1939.
The tenders will be opened on the 13th September 1939.

No. S. P. C. 4795-805, dated 18th August 1939.

To

The Firms dealing in Khaki Woollen Putties.

Enquiry No. 3621.

KHAKI WOOLLEN PUTTIES.

DEAR SIR/GENTLEMEN,

Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the form printed below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Khaki Woollen Putties", with the above enquiry Number.

This enquiry will be closed on the 1st September 1939.

Schedule.

Item No.	Description of material offered	Quantity	Price quoted F. O. R.	Time of delivery
	Khaki Woollen Putties 10′ long 4½″ wide complete with tape 5′ 10″ long to match the shade of the putti	1,700 pairs	*Mysore.*	

(1) Samples should accompany your quotation.
(2) Time of delivery should be definitely specified.

Yours faithfully,
T. RANGASWAMI,
Secretary,
Stores Purchase Committee.

No. S. P. C. 4822, dated 17th August 1939.

NOTICE.

Enquiry No. 3568.

Sealed tenders will be received by the Secretary, Stores Purchase Committee, for the supply of one additional 300 K.W. Frequency Changer set for Forbes Transformer Station, Mysore, up to 30th October 1939.

Intending tenderers may, on application to the Secretary, Stores Purchase Committee, obtain the requisite tender forms on which tenders should be submitted. Applications should be accompanied by a cash remittance of Rs. 10 which is the price fixed for a set of forms and which is not refundable.

Cheques, postage stamps or postal orders will not be accepted towards the cost of forms nor will the forms be sent by V.P.P.

By Order,
T. RANGASWAMI,
Secretary,
Stores Purchase Committee.